

## Spec # 9

### **UNDERGROUND SERVICE TO METER AND SERVICE DISCONNECT ON PEDESTAL**

SINGLE PHASE, 120/240 VOLTS, 3 WIRE SERVICE, 100 AMP MINIMUM

#### **GENERAL**

1. Member to obtain meter pan from Co-op or independently purchase a meter cabinet disconnect combination and install on house at his/her expense.
2. All service entrance equipment to be supplied and installed on pedestal by member, including proper size conduit from meter base to below ground level. Conduit shall be galvanized steel or rigid non-metallic conduit (Schedule 80 PVC). It shall be of proper size as indicated below and securely fastened to pedestal with suitable clamps.
3. Member shall provide service entrance cable to reach from designated Cooperative owned pole transformer or pad mount transformer to meter base on pedestal. Member shall provide and install the bottom ten feet of conduit, on Cooperative owned pole. Conduit shall be either galvanized steel or Schedule 80 PVC. The remaining conduit, clamps, couplings, etc., required on the pole will be provided by the member and installed by the Cooperative.

#### **PEDESTAL SPECIFICATIONS**

As shown in diagram on reverse side.

#### **GROUNDING**

1. Ground wire shall be one continuous length, without splice or joint, from main switch to grounding electrodes. Suitable clamp must connect ground wire securely to two driven ground rods - minimum 6' apart in undisturbed earth. Grounding shall meet the N.E.C. codes for new construction.
2. Grounding electrodes must be rods: 5/8" x 8' solid rod, either galvanized or copper clad.
3. PVC conduit installed on the pole and/or pedestal requires a 3 wire cable from the pole to the pedestal. If the metal conduit is used on either end, it must be bonded to the meter box and/or the service panel.
4. Metal conduit used on the pole and pedestal requires a 3 wire cable plus a ground wire bonded from the metal conduit to the meter box on the pedestal or the service panel.
5. If metallic conduit is used from the meter box to the service panel, bonding bushings must be used at each location and a 3 wire cable may be use between the meter box and the service panel.
6. On all of the above, 2 ground rods must be installed at the pedestal.

## Spec # 9

### NOTES

1. All installations to be made according to the diagram on reverse side.
2. All materials to be approved by the Underwriters Laboratories.
3. All wiring to be in conformance with the National Electric Code and the National Electric Safety Code, current edition, and certified by a Cooperative approved inspection agency.
4. Always have a qualified electrician take care of your wiring needs.
5. Members not following these minimum specifications may be refused service connection.
6. Service connections and/or meter approval shall be done only by authorized Cooperative personnel.
7. Reduced neutral may be allowed.

### TRENCH

The trench depths specified are minimum and are measured from final grade.

The trench shall be dug so that the bottom has a level grade and the bottom of the trench shall be relatively smooth, undisturbed earth or tamped earth or sand. Large rocks, stones, and gravel in excess of one inch shall be removed from the bottom and sides of trench. Where this cannot be done, a three inch layer of clean masonry sand shall be placed in the bottom of the trench, and screened dirt (using a one inch mesh screen) shall be used for backfill. TRENCH SHALL NOT BE FILLED WITH EXCESS CONSTRUCTION MATERIALS SUCH AS CONCRETE BLOCK, LUMBER, DRYWALL, ETC.

If proper depth cannot be maintained from final grade, galvanized conduit or Schedule 80 PVC must be used. All trenches parallel to the building foundation shall be no closer than four feet.

The trench shall be backfilled as described above as soon as possible after the placing of the cable. The top twelve inches of such backfill shall be well tamped while backfilling, and shall be banked over the top of the ditch to provide for settling of the backfill.

Duct shall be installed under driveways, patios, or other paved areas. Duct may be either galvanized pipe, Type II Fiberduct or Schedule 80 PVC.

\*Members not following these minimum specifications may be refused service connection.

ITEM	MATERIAL	SERVICE		
		100 AMP SERVICE	200 AMP SERVICE	400 AMP SERVICE
1	Copper Wire, Type THW in conduit	#4	#2/0	500 MCM
2	Aluminum Wire, Type THW in Conduit	#2	#4/0	750 MCM
3	Minimum Conduit Size	2"	2"	3"   3 1/2"
4	Minimum Conduit Size For UG Service Conductors	2"	2"	4"
5	Copper Ground Wire To Driven Grounding Electrodes	Minimum #6	Minimum #4	Minimum #1/0

# Spec # 9

